

SECTION 26 05 48

VIBRATION AND SEISMIC CONTROLS FOR ELECTRICAL SYSTEMS

PART 1 - DESIGN DIRECTIVES

1.1 DESIGN CRITERIA

- A. The engineer shall determine where seismic restraints are required and detail the type of restraint in the design specifications and provide a typical installation detail in design drawings.

PART 2 - PRODUCTS

2.1 NO SPECIAL REQUIREMENTS

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Seismic restraints shall be installed by the appropriate tradesperson in strict accordance with the manufacturer's installation instructions. Restraints shall be supplied by a reputable and certified manufacturer and shall not be fabricated on the job site.

END OF SECTION