

**DIVISION 3**

**CONCRETE**

**1.1 DESIGN CRITERIA**

- A. Comply with the Dartmouth Design and Construction Guidelines as established in this Section and through consultation with the Dartmouth Project Manager.

**1.2 GUIDELINES**

**A. Section 03 30 00 - Cast-In-Place Concrete:**

- 1. Structural concrete design documents shall be stamped by the Engineer-of-Record.
- 2. Polished Finishes: Mock-up required, testing for slip resistance required. Concrete stain not recommended.
- 3. Refer to Division 32 sections for sidewalks, ductbanks, exterior stairs, site pads and bases.

**B. Section 03 35 15 - Concrete Finishing:**

- 1. Polished concrete finish in public areas should be avoided. If it is to be considered, consult with the Dartmouth PM and require a contractor with exceptional experience. Dartmouth representatives will want to review comparable projects completed by subcontractor prior to selection. Mockup required of a size and scale appropriate for quality review.

**END OF DIVISION**