

SECTION 06100

ROUGH CARPENTRY

Notes to A/E:

1. Review blocking requirements with college during design review.
2. Use of 16 gauge sheet metal blocking band at 6'0" aff should be considered in restrooms, kitchens, labs, and any other areas requiring extensive blocking in present design or conceivably in future renovation or re-use projects.
3. The architect shall review all STC rating needs for the project with the college early in the design process. Lawri Copley (address and telephone number available at the Facility Planning Office) is a sound consultant engaged frequently by Dartmouth College. The architect shall review the sound related needs of the project with Lawri unless otherwise agreed with FPO and FOM.

END OF SECTION