

SECTION 15810

HUMIDIFIERS

PART 1 DESIGN DIRECTIVES

1.1 DESIGN CRITERIA

- A. Drain piping serving humidifiers shall be copper. Steel pipe is not allowed.
- B. Drain pans in humidifiers shall be stainless steel. Carbon steel drain pans are not acceptable.

PART 2 MATERIALS

TO BE COMPLETED AT A LATER DATE

PART 3 EXECUTION

TO BE COMPLETED AT A LATER DATE

END OF SECTION 15810