

**SECTION 16150**

**SEISMIC RESTRAINT FOR ELECTRICAL SYSTEMS AND EQUIPMENT**

**Part 1 -Design Directives**

The engineer shall determine where seismic restraints are required and detail the type of restraint in the design specifications and provide a typical installation detail in design drawings.

**Part 2 -Products**

No designated manufacturers

**Part 3 -Execution**

Seismic restraints shall be installed by the appropriate tradesperson in strict accordance with the manufacturers installation instructions. Restraints shall be supplied by a reputable and certified manufacturer and shall not be fabricated on the job site.